

MEMORANDUM

TO: Board of Trustees
FROM: Jill J. White
DATE: June 9, 2009
SUBJECT: **Safety Report for 2008-09**

Attached is the 2008-09 College Safety Report for your review and approval.

JW:cl

RECOMMENDATION:

The Board of Trustees approves the College's Safety Report for 2008-09, as presented.

6-9-09

Date


Interim President

FISCAL YEAR 2008-2009

The Following is a complete list of Northwest Florida State College buildings inspected this year: .

<u>BUILDING</u>	<u>INSPECTED</u>
A	YES
B	YES
C-1	YES
C-2	YES
D	YES
E	YES
F	YES
F-1	YES
F-2	YES
F-3	YES
F-4	YES
F-5	YES
F-6	YES
G	YES
G-1	YES
G-2	YES
G-3	YES
H	YES
J	YES
K	YES
L	YES
LRC	YES
M	YES
P	YES
Q	YES
R	YES
S	YES
BLD-1	YES
BLD-2	YES
BLD-3	YES
BLD-4	YES
BLD-5	YES
BLD-6	YES
BLD-7	YES

BLD-8
SIKES
CNC-1
CNC-2

YES
YES
YES
YES

Inspector: Sam Jones
 FLORIDA STATE FIRE SAFETY
 CERT NUMBER: 118535

SREF
 2008-2009

NORTHWEST FLORIDA STATE COLLEGE

990-82051

Campus

100 College Blvd, Niceville FL 32579

Signed: Sam Jones

Date:

SREF			PRIORITY	LOCATION		ESTIMATED COST	DEFICIENCY DESCRIPTION AND CORRECTIVE ACTION REQUIRED	# OF TIMES DEF. CITED BEFORE	SCHEDULED FOR CORRECTION NOT LATER THAN	PRIOR FISCAL YEAR DEFICIENCY STATUS
SEC	PARA	SUB PARA		BLDG	ROOM				5/30/2009	
				A	1st Flr. Corr.		Emergency light out		5/30/2009	
					2nd Flr. Corr.		Emergency light out		5/30/2009	
				B	102		Exit light out		5/30/2009	
					103		Emergency light out		5/30/2009	
					105		Emergency light out		5/30/2009	
					114		Exit light out		5/30/2009	
				C	ALL		No deficiencies at this time		5/30/2009	
				D	142		Remove items stored		5/30/2009	
					123		Emergency light out		5/30/2009	
				E	49		Exit light out		5/30/2009	
					44		Exit light out		5/30/2009	
					233		Emergency light out		5/30/2009	
				F	Mens		Emergency light out		5/30/2009	
					Womens		Emergency light out		5/30/2009	
				F-1	Mens		Emergency light out		5/30/2009	
				F-2	All		No deficiencies at this time		5/30/2009	
				F-3	All		No deficiencies at this time		5/30/2009	
				F-4	Entry		Exit light out		5/30/2009	
				F-5	ALL		No deficiencies at this time		5/30/2009	
				F-6	All		No deficiencies at this time		5/30/2009	
				G	All		No deficiencies at this time		5/30/2009	
				G-1	ALL		No deficiencies at this time		5/30/2009	
				G-2	All		No deficiencies at this time		5/30/2009	
				G-3	ALL		No deficiencies at this time		5/30/2009	
				H	Entry		Exit light out		5/30/2009	
				J	Gallery		Exit light out		5/30/2009	
					E. Hallway		Emergency light out		5/30/2009	

Signed: *Sam Jones*

Date:

SREF			PRIORITY	LOCATION		ESTIMATED COST	DEFICIENCY DESCRIPTION AND CORRECTIVE ACTION REQUIRED	# OF TIMES DEF. CITED BEFORE	SCHEDULED FOR CORRECTION NOT LATER THAN	PRIOR FISCAL YEAR DEFICIENCY STATUS
SEC	PARA	SUB PARA		BLDG	ROOM					
					508		Emergency light out		5/30/2009	
				J	509		Emergency light out		5/30/2009	
					512		Emergency light out		5/30/2009	
					515		Emergency light out		5/30/2009	
					Amp. Restrms		Emergency light out		5/30/2009	
					Ampitheater					
					408		Emergency light out		5/30/2009	
					409		Emergency light out		5/30/2009	
					404		Emergency light out		5/30/2009	
					405		Emergency light out		5/30/2009	
					406		Emergency light out		5/30/2009	
				K			No deficiencies		5/30/2009	
				L	102		Emergency light out		5/30/2009	
					103		Emergency light out		5/30/2009	
					111		Emergency light out		5/30/2009	
					133		Emergency light out		5/30/2009	
				M	Entry		Exit light out		5/30/2009	
				Q	103		Exit light out		5/30/2009	
				CNC	109		Emergency Exit Blocked		5/30/2009	
				Sikes	301		Emergency light out		5/30/2009	
					302		Emergency light out		5/30/2009	
					303		Emergency light out		5/30/2009	
					304		Emergency light out		5/30/2009	
				FWB	410		Emergency light out		5/30/2009	

Niceville Fire Department
216 North Partin Drive
Niceville, Florida 32578
Office 850-729-4021

Address: 1001 College Boulevard West **Occupant Name:** Okaloosa Collegiate High School
Inspection Type: Annual **Property Owner:** Sam Jones
Inspection Date: 6/1/2009 **Requested By:**
Inspected By: Mike Valenzuela
729-4021

Pass Fail N/A

NFPA 01, Uniform Fire Code, Florida Edition

Floor 1

Chapter 4 General Requirements

4.4.3.1.2 Excerpt: No lock or fastening devise shall be permitted tha...

Chapter 10 General Fire Safety

10.9.1 Where Required.

10.12.1 Access Box(es).

10.13.1.1 Excerpt: New and existing buildings shall have approved add...

10.17.1 Excerpt: Outside storage of combustible materials shall not...

10.17.6 Excerpt: Combustible storage in the open shall not exceed 2...

Chapter 11 Building Services

11.1.5 Excerpt: Extension cords shall not be used as a substitute ...

11.1.5.1 Multiplug Adapters.

11.1.5.3.5 Excerpt: Extension cords and flexible cords shall not be af...

Chapter 13 Fire Protection Systems

13.1.3 Excerpt: Obstructions shall not be placed or kept near fire...

13.1.4 Excerpt: A minimum clear space shall be maintained to permi...

13.3.3.2 Excerpt: A sprinkler system installed in accordance with th...

13.3.3.3.1 Excerpt: The owner or occupant shall provide ready accessib...

13.6.3.2 Excerpt: Portable fire extinguishers shall be maintained in...

13.6.3.3 Excerpt: Fire extinguishers shall be conspicuously located ...

Chapter 14 Means of Egress

14.4.1 Excerpt: Means of egress shall be continuously maintained f...

14.5.2.2 Excerpt: Locks, if provided, shall not require the use of a...

14.10.1.1 Excerpt: Exits shall be located and exit access shall be ar...

14.14.1.2 Exits.

Chapter 50 Commercial Cooking Equipment

50.5.2.1 Excerpt: An inspection and servicing of the fire-extinguish...

50.5.4.1 Excerpt: Upon inspection, if found to be contaminated with ...

Pass Fail N/A

NFPA 101, Uniform Fire Code, Florida Edition

Floor 1

Chapter 7 Means of Egress

- 7.1.10.1 Excerpt: Means of egress shall be continuously maintained f...
 7.1.10.2.1 Excerpt: No furnishings, decorations, or other objects sha...
 7.2.1.5.1 Excerpt: Doors shall be arranged to be opened readily from ...
 7.2.1.5.2 Excerpt: Locks, if provided, shall not require the use of a...
 7.2.1.5.9.1 Excerpt: The releasing mechanism for any latch other than e...
 7.2.2.3.2.1 Excerpt: Stairs shall have landings at door openings, excep...
 7.2.2.4.1.1 Excerpt: Stairs and ramps shall have handrails on both side...
 7.5.2.2 Excerpt: Exit access and exit doors shall be designed and a...
 7.8.1.1 Excerpt: Illumination of means of egress shall be provided ...
 7.9.2.1 Excerpt: Emergency illumination shall be provided for not l...
 7.10.1.5.1 Excerpt: Access to exits shall be marked by approved, readi...
 7.10.2 Directional Signs.
 7.10.9.2 Testing.

Chapter 9 Building Service and Fire Protection Equipment

- 9.6.1.3 Excerpt: A fire alarm system required for life safety shall...
 9.7.4.1 Excerpt: Where required by the provisions of another sectio...
 9.7.5 Maintenance and Testing.

Chapter 12 New Assembly Occupancies

- 12.2.5.1.3 Excerpt: Dead-end corridors shall not exceed 6100 mm (240 i...

Chapter 39 Existing Business Occupancies

- 39.3.5 Extinguishment Requirements.

Pass Fail N/A

Chapter 633 Florida Statutes 2003

Floor 1

Chapter 633 - Florida Statutes 2003 Fire Prevention and Control

- 633.071 Standard service tag required on all fire extinguishers and preengineered systems; serial number required on all portable fire extinguishers.

Congratulations! You have passed your inspection. If you have any questions, please call our office.

Company Representative:



Sam Jones
6/1/2009